


TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD**WELL LOG AND DRILLING REPORT**Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

961778

WELL LOCATIONCounty Stark Township JacksonOwner/Builder Domer/Heritage Homes
(Circle One or Both) First LastAddress of Well Location 9609 Cliffview
Number Street NameCity Mass Zip Code +4 44646Permit No. 23616 Section/Lot No. _____
(Circle One or Both)Location of Well in State Plane
coordinates, if available:N ☐ X ☒ +/- _____ ft. or mS ☐ Y ☐ +/- _____ ft. or m

Elevation of Well +/- _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____Source of Coordinates: ☒ GPS ☐ Survey ☐ Other _____Sketch a map showing distance well lies from numbered state highways, street
intersections, county roads, buildings or other notable landmarks. If latitude and
longitude are available please include here: N 40° 54' 360'
W 081° 31' 677'**WELL TEST***Pre-Pumping Static Level 69' ft. Date 8-1-2011Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____☐ Air ☐ Bailing ☐ Pumping* ☐ Other _____Test Rate 12 gpm Duration of Test 3 hrs.Feet of Drawdown 100 ft. Sustainable Yield 9 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality clear**PUMP/PITLESS**Type of pump Submersible Capacity 10 gpmPump set at 105 ft. Pitless Type Baker-5A0Pump installed by Hall drilling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Hall drillingAddress 2317 Leo Ave SWCity, State, Zip Canton OH 44706Signed [Signature] Date 8-7-11ODH Registration Number 3292**CONSTRUCTION DETAILS**☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other _____**BOREHOLE/CASING** (measured from ground surface)1 ☐ Borehole Diameter 8 inches Depth 113 ft.Casing Diameter 5 in. Length 110 ft. Thickness SDR-21 in.2 ☐ Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 18 ft. inType 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other _____Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other _____**SCREEN**Diameter 5 Slot Size 20 Screen Length 3 ft.Type wire wrap Material stainless steelSet Between 100 ft. and 113 ft.**GRAVEL PACK** (Filter Pack)Material/Size gravel Volume/Weight Used 300lbMethod of Installation displacementDepth: Placed FROM 113 ft. TO 105 ± ft.**GROUT**Material bentonite Volume/Weight Used 160galMethod of Installation premix pipeDepth: Placed FROM 105 ± ft. TO surface ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown clay	0'	15'
clay/brown and gravel	15'	45'
boulder + cobbles	45'	75'
sand + gravel	75'	90'
coarse sand + gravel	90'	115'

East

West

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy