

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

CONSTRUCTION DETAILS

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

A hand-drawn map of the FELDON CT area. A horizontal line represents the road, with 'FELDON CT' written above it. To the left of the road is 'West' and to the right is 'East'. Below the road, a vertical line descends to a box labeled 'HOME'. To the left of the home are two wells: 'NEW WELL' and 'OLD WELL', each with a small circle representing the well head. Below the home is a small square labeled 'SEPTIC' with a line connecting it to the home.

WELL TEST*

Pre-Pumping Static Level 25 ft. Date 9-7-03
Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other _____
☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____
Test Rate 15 gpm Duration of Test 2 hrs.
Feet of Drawdown 0 ft. Sustainable Yield 15 gpm
(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No
Quality CLEAR

PUMP/PITLESS

Type of pump 1/2 HP SUB Capacity 10 gpm
Pump set at 40 ft. Pitless Type PULL THROUGH
Pump installed by BAUER

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Bauer Well Drilling
Address 10621 Miller Ave NW
City, State, Zip Canal Winchester, OH 43110

Signed Yimm Road Date _____

ODH Registration Number 2473

DRILLING LOG*

COURSE GRAVEL	51	52
---------------	----	----

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 9/7/03 Total Depth of Well 52 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy