

TYPE OR USE PEN  
SELF TRANSCRIBING  
PRESS HARD

# WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources  
Division of Water, 1939 Fountain Square Drive  
Columbus, Ohio 43224-9971 Voice (614) 265-6739 Fax (614) 447-9503

965231

WELL LOCATION

County MORGAN Township PENN

Owner/Builder ROBERT PENKOSZ

Address of Well Location 9405. BALDABLE RD

City STOCKPORT Zip Code +4 43787

Permit No. 15-2003 Section/Lot No.

Location of Well in State Plane coordinates, if available: Use of Well DOMESTIC

N X 39° 35' 104 +/- 5 ft. or m

S WY 081° 49' 768 +/- 5 ft. or m

Elevation of Well 875 +/- 5 ft. or m

Datum Plain: ☒ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: North Long: South

House

septic

CO. Rd. 42

Well

CONSTRUCTION DETAILS

☒ Rotary ☐ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 12 inches Depth 25 ft.

Casing Diameter 8 in. Length 27 ft. Thickness SD 17 in.

2 ☐ Borehole Diameter 8 inches Depth 100 ft.

Casing Diameter 4.5 in. Length 90 ft. Thickness SD 17 in.

Casing Height Above Ground 18 ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐

2 ☐ Steel 2 ☐ Galv. 2 ☒ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐

2 ☐ Threaded 2 ☐ Welded 2 ☒ Other

SCREEN

Diameter 4.5 Slot Size 1/16 Screen Length 20 ft.

Type SAWCUT Material PVC

Set Between 90 ft. and 70 ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation N/A

Depth: Placed FROM ft. TO ft.

GROUT

Material PORTLAND CEMENT Volume/Weight Used

Method of Installation PUMPED FROM BOTTOM - TOP

Depth: Placed FROM 0 ft. TO 25 ft.

DRILLING LOG\*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

|                | From | To  |
|----------------|------|-----|
| Topsoil        | 0    | 3   |
| Brown clay     | 3    | 5   |
| SANDSTONE      | 5    | 10  |
| SHALE          | 10   | 20  |
| BLUE SANDSTONE | 20   | 30  |
| LIME ROCK      | 30   | 32  |
| BLUE SANDSTONE | 32   | 59  |
| SHALE          | 59   | 100 |

WRT @ 30' and 59'

WELL TEST\*

Pre-Pumping Static Level 20 ft. Date Nov 15/03

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☒ Air ☐ Bailing ☐ Pumping\* ☐ Other

Test Rate 10 gpm Duration of Test 1 hrs.

Feet of Drawdown 100 ft. Sustainable Yield 2.5 gpm

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☒ Yes ☐ No Flowing Well? ☒ Yes ☐ No

Quality CLEAR

PUMP/PITLESS

Type of pump Submersible Capacity 10 gpm

Pump set at 93 ft. Pitless Type 1-hole ADAPTOR

Pump installed by HOOVER WATER SYSTEMS

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm HOOVER WATER SYSTEMS

Address PO BOX 11

City, State, Zip WATERFORD OH 45786

Signed [Signature] Date Nov 15/03

ODH Registration Number 02560

(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 10/20/03 Total Depth of Well 100 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.  
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971  
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy