

CONSTRUCTION DETAILS

GROUT	
Material <u>Pensol</u>	Volume/Weight Used <u>150 LB</u>
Method of Installation <u>Poured</u>	
Depth: Placed FROM <u>Surface</u>	ft. TO <u>5</u> ft

Hand-drawn map showing the intersection of Co Rd 16 and Co Rd K. A rectangular signpost labeled "House" is located on Co Rd K, north of the intersection. The area is labeled "O'Kwell" in the top right, "West" on the left, "North" at the top, and "South" at the bottom.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

From	To
0	1 1/2
1 1/2	6
6	26

Pre-Pumping Static Level 5 ft. Date 12-1-03
 Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other _____
☐ Air ☐ Bailing ☒ Pumping* ☐ Other _____
 Test Rate 3 gpm Duration of Test 1 hrs.
 Feet of Drawdown 10 ft. Sustainable Yield 3 gpm
 *(Attach a copy of the pumping test record, per section 1521.05, ORC)
 Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No
 Quality Clear

Type of pump Myers Lustler Capacity 12 gpm
Pump set at 24 ft. Pitless Type PA100
Pump installed by Dawson Michel Mahlman Drilling
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm Dawson, Michel, Mahlman Drilling
Address 941 E. Eleventh St
City, State, Zip Ottawa, OH 45875
Signed David Michel Date 12-11-03
ODH Registration Number 01445

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11-25-03 Total Depth of Well 26 ft

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy