

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

984081

WELL LOCATION

CONSTRUCTION DETAILS

County Muskingum Township Cass

Owner/Builder Gene Hindle
(Circle One or Both) First Last

Address of Well Location 6115 School House Rd.
Number Street Name

City Dresden Zip Code +4 43821

Permit No. 370937 Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available:
N ☒ X +/- ft. or m
S ☐ Y +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other

Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 Borehole Diameter 8 inches Depth 60 ft.
Casing Diameter 5 in. Length 60 ft. Thickness 250 in.

2 Borehole Diameter inches Depth ft.
Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground ft.

Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐ Other
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

Joints 1 ☐ Threaded 1 ☐ Welded 1 ☒ Solvent 1 ☐ Other
2 ☐ 2 ☐ 2 ☐ 2 ☐ Other

SCREEN

Diameter Slot Size Screen Length ft.

Type Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Ben Seal Volume/Weight Used 120 lbs

Method of Installation Free Fall

Depth: Placed FROM 60 ft. TO 0 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Shale	0	18
Grey Clay	18	27
Grey Shale	27	60
Grey Sandstone	60	95
Grey Shale	95	200
Black Limestone	200	225
Grey Sandstone	225	260

WELL TEST*

Pre-Pumping Static Level 150 ft. Date 5/10/06

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 10+ gpm Duration of Test 2 hrs.

Feet of Drawdown 225 ft. Sustainable Yield 6 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality Good

PUMP/PITLESS

Type of pump Simmons Red Jacket Capacity 10 gpm

Pump set at 225 ft. Pitless Type Simmons

Pump installed by CW BEVARO

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm BEVARO Drilling

Address 2540 Mt Vernon Rd.

City, State, Zip NEWARK OH 43055

Signed Carl Bevaro Date 5/10/06

ODH Registration Number 02541

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 4/13/06 Total Depth of Well 260 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy