

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

984143

WELL LOCATION

CONSTRUCTION DETAILS

County CARROLL Township BROWN

Owner/Builder (Circle One or Both) RAY KROLL
First Last

Address of Well Location 2128 LEISURE RD
Number Street Name

City MINERVA Zip Code +4 44657

Permit No. 113-05 Section/Lot No. 10
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Domestic
N X 40°-42'-974 +/- ft. or m
W Y 081°-08'-138 +/- ft. or m
Elevation of Well 1017 +/- ft. or m
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source Topo
Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 9.5 inches Depth 32 ft.
Casing Diameter 5.5 in. Length 30 ft. Thickness .265 in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 18" ft.

Type ☐ Steel ☐ Galv. ☒ PVC ☐ Other

Joints ☐ Threaded ☐ Welded ☒ Solvent ☐ Other

SCREEN

Diameter 5" Slot Size .020 Screen Length 3 ft.
Type TS SS Material stainless
Set Between 29' ft. and 32' ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____
Method of Installation _____
Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material BENS EAL Volume/Weight Used 650lb
Method of Installation PRY POUR ALONG CASING
Depth: Placed FROM 26 ft. TO SURFACE ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
TOPSOIL	0	2
BROWN SAND AND CLAY	2	12
BROWN SAND	12	18
GRAY SAND	18	27
SAND AND GRAVEL	27	32

WATER AT 30 ft

WELL TEST*

Pre-Pumping Static Level 11 ft. Date 11-24-05

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other

☐ Air ☒ Bailing ☐ Pumping* ☐ Other

Test Rate 20 gpm Duration of Test 1 hrs.

Feet of Drawdown 9 ft. Sustainable Yield 20 plus gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ No

Quality CLEAN PH. 6.6

PUMP/PITLESS

Type of pump Submersible Capacity 7 gpm

Pump set at 26 ft. Pitless Type pull through adapter

Pump installed by SCARLOTT Well Drilling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm SCARLOTT Well Drilling

Address 7990 APRIL RD

City, State, Zip SALINEVILLE, OHIO 43945

Signed Mike Scarlott Date 11-27-05

ODH Registration Number 002672

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 11-26-05 Total Depth of Well 32 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy