

WELL LOG AND DRILLING REPORT

986148

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION	CONSTRUCTION DETAILS
County <u>Fairfield</u> Township <u>Clear Creek</u>	☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other
Owner/Builder <u>Chris Gobel</u> (Circle One or Both) First Last	BOREHOLE/CASING (measured from ground surface)
Address of Well Location <u>9695 Valentine Rd</u> Number Street Name	1 ☐ Borehole Diameter <u>5"</u> inches Depth <u>88'</u> ft. Casing Diameter <u>5"</u> in. Length <u>27-95</u> ft. Thickness <u>.244</u> in.
City <u>Stoutsville</u> Zip Code +4 <u>43154</u>	2 ☐ Borehole Diameter _____ inches Depth _____ ft. Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Permit No. <u>2007-058</u> Section/Lot No. _____ (Circle One or Both)	Casing Height Above Ground <u>14"</u> ft.
Location of Well in State Plane coordinates, if available: N ☐ X _____ +/- _____ ft. or m S ☐ Y _____ +/- _____ ft. or m	Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other 2 ☐ 2 ☐ 2 ☐ 2 ☐
Elevation of Well _____ +/- _____ ft. or m	Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other 2 ☐ 2 ☐ 2 ☐
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____	SCREEN
Source of Coordinates: ☒ GPS ☐ Survey ☐ Other	Diameter _____ Slot Size _____ Screen Length _____ ft.
Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat <u>39°33'46"</u> Long <u>81°24'40"</u> 	Type _____ Material _____
	Set Between _____ ft. and _____ ft.
	GRAVEL PACK (Filter Pack)
	Material/Size _____ Volume/Weight Used _____
	Method of Installation _____
	Depth: Placed FROM _____ ft. TO _____ ft.
	GROUT
	Material <u>Benseal</u> Volume/Weight Used <u>100# / 63</u>
	Method of Installation <u>Back Filled as Driven</u>
	Depth: Placed FROM <u>26'-7"</u> ft. TO <u>Surface</u> ft.
	DRILLING LOG*
	INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.
	Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.
	From To
	Gray Clay & Gravel mixed. 0' 25'
	GRAY Sandy Shale 25' 88'
	First water at 26'
	Second water at 81'
WELL TEST*	
Pre-Pumping Static Level <u>22'</u> ft. Date <u>5-5-07</u>	
Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other	
☐ Air ☒ Bailing ☐ Pumping* ☐ Other	
Test Rate <u>12</u> gpm Duration of Test <u>2</u> hrs.	
Feet of Drawdown <u>58'</u> ft. Sustainable Yield <u>10</u> gpm	
*(Attach a copy of the pumping test record, per section 1521.05, ORC)	
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No	
Quality <u>Clear</u>	
PUMP/PITLESS	
Type of pump <u>Submersible</u> Capacity <u>10</u> gpm	
Pump set at <u>80'</u> ft. Pitless Type <u>Adapter</u>	
Pump installed by <u>Buckeye Valley</u>	
I hereby certify the information given is accurate and correct to the best of my knowledge.	
Drilling Firm <u>Buckeye Valley Well Drilling Inc</u>	
Address <u>10122 Tarlton Rd</u>	
City, State, Zip <u>Circleville, Ohio, 43113</u>	
Signed <u>Sam Danna</u> Date <u>5-5-07</u>	
ODH Registration Number <u>001516</u>	
	*(If more space is needed to complete drilling log, use next consecutively numbered form.)
	Date of Well Completion <u>5-5-07</u> Total Depth of Well <u>88'</u> ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
 ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
 Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy