


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

989192

WELL LOCATION**CONSTRUCTION DETAILS**County Ashtabula Township SheffieldOwner/Builder Tatjana Degan
(Circle One or Both) First LastAddress of Well Location 2541 Stanhope Kelloggsville
Number Street NameCity Kingsville Zip Code +4 44048Permit No. 88 Section/Lot No. _____
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well HomeN X +/- _____ ft. or mS Y +/- _____ ft. or mElevation of Well +/- _____ ft. or mDatum Plain: NAD27 NAD83 Elevation Source _____Source of Coordinates: GPS Survey Other _____Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____
NorthRotary ☐ Cable ☒ Augered ☐ Driven ☐ Other ☐**BOREHOLE/CASING** (measured from ground surface)1 Borehole Diameter 4 inches Depth 45 ft.Casing Diameter 4 in. Length 18 ft. Thickness _____ in.

2 Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 2 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other _____2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other _____Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐ Other _____2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other _____**SCREEN**

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUTMaterial Bentonite Volume/Weight Used 40#Method of Installation dry drivenDepth: Placed FROM 0 ft. TO 18 ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Clay	0	8
Gray Clay	8	18
Shale	18	45
Water @	20	25

WELL TEST*Pre-Pumping Static Level 8 ft. Date 9-23-05Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other _____☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____Test Rate 30 gpm Duration of Test 2 hrs.Feet of Drawdown 20 ft. Sustainable Yield 30 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? Yes No Flowing Well? ☐ Yes ☒ NoQuality Clear**PUMP/PITLESS**Type of pump submersible Capacity 10 gpmPump set at 25 ft. Pitless Type pull thruPump installed by Kaplan

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Kaplan IncAddress 7405 SR167ECity, State, Zip Jefferson OH 44104Signed Russell Kaplan Date 11-7-05ODH Registration Number 619

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 9-23-05 Total Depth of Well 45 ft.Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy