


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

989193

WELL LOCATION**CONSTRUCTION DETAILS**County Ashtabula Township LenoxOwner/Builder Glen + Christine Smith
(Circle One or Both) First LastAddress of Well Location 3362 Lenox New Lyme Rd.
Number Street NameCity Jefferson Zip Code +4 44047Permit No. 117 Section/Lot No. _____
(Circle One or Both)Location of Well in State Plane
coordinates, if available:Use of Well HomeN ☒ X _____ +/- _____ ft. or mS ☐ Y _____ +/- _____ ft. or m

Elevation of Well _____ +/- _____ ft. or m

Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____Source of Coordinates: ☐ GPS ☐ Survey ☐ Other _____Sketch a map showing distance well lies from numbered state highways, street
intersections, county roads, buildings or other notable landmarks. If latitude and
longitude are available please include here: Lat: _____ Long: _____
North**WELL TEST***Pre-Pumping Static Level 6 ft. Date 10-12-05Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other _____☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____Test Rate 2.5 gpm Duration of Test 1 hrs.Feet of Drawdown _____ ft. Sustainable Yield 2.5 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? Yes ☐ No ☒ Flowing Well? Yes ☐ No ☒Quality clear**PUMP/PITLESS**

Type of pump _____ Capacity _____ gpm

Pump set at _____ ft. Pitless Type _____

Pump installed by _____

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm _____

Address _____

City, State, Zip _____

Signed Russell Kopsch Date 10-21-05ODH Registration Number 619☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other _____**BOREHOLE/CASING** (measured from ground surface)1) Borehole Diameter 8 inches Depth 50 ft.Casing Diameter 8 7/8 in. Length 21 ft. Thickness .188 in.

2) Borehole Diameter _____ inches Depth _____ ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

Casing Height Above Ground 2 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ Other _____Joints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐2 ☐ 2 ☐ 2 ☐ 2 ☐ Other _____**SCREEN**

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUTMaterial Bentonite Volume/Weight Used 50#Method of Installation dry drivenDepth: Placed FROM 0 ft. TO 21 ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown Clay	0	8
Gray Clay	8	21
Shale	21	50
Water @	40	50

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy