

TYPE OR USE PEN  
SELF TRANSCRIBING  
PRESS HARD

## WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources  
Division of Water, 1939 Fountain Square Drive  
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

989349

## WELL LOCATION

County Columbiana Township Knott

Owner/Builder Harold Benner  
(Circle One or Both) First Last

Address of Well Location 23753 Center  
Number Street Name

City Homeworth Zip Code +4 44634

Permit No. 8577 Section/Lot No. \_\_\_\_\_  
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well Home

N X 0-5-4 N. +/- ft. or m

S Y 81 0326 W +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: NAD27 NAD83 Elevation Source

Source of Coordinates: ☐ GPS ☐ Survey ☐ Other \_\_\_\_\_

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: \_\_\_\_\_ Long: \_\_\_\_\_

North

South

## WELL TEST\*

Pre-Pumping Static Level 45 ft. Date \_\_\_\_\_

Measured from: ☐ Top of Casing ☒ Ground Level ☐ Other \_\_\_\_\_

☐ Air ☒ Bailing ☐ Pumping\* ☐ Other \_\_\_\_\_

Test Rate 6 gpm Duration of Test 1 hrs.

Feet of Drawdown 55 ft. Sustainable Yield \_\_\_\_\_ gpm

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? Yes No Flowing Well? ☐ Yes No

Quality \_\_\_\_\_

## PUMP/PITLESS

Type of pump Sub m. Capacity 10 gpm

Pump set at 90 ft. Pitless Type Dickin

Pump installed by Driller

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm READSHAW WELL DRILLING

Address 3593 Butler Grange Road

City, State, Zip Salem Ohio

Signed Wm Readshaw Date 9/29/10

ODH Registration Number 468

## CONSTRUCTION DETAILS

Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other \_\_\_\_\_

**BOREHOLE/CASING** (measured from ground surface)

1 Borehole Diameter 6 inches Depth 110 ft.

Casing Diameter 6 in. Length 83 ft. Thickness 1.88 in.

2 Borehole Diameter \_\_\_\_\_ inches Depth \_\_\_\_\_ ft.

Casing Diameter \_\_\_\_\_ in. Length \_\_\_\_\_ ft. Thickness \_\_\_\_\_ in.

Casing Height Above Ground \_\_\_\_\_ ft.

Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other \_\_\_\_\_

2 ☐ Threaded 2 ☒ Welded 2 ☐ Solvent 2 ☐ Other \_\_\_\_\_

## SCREEN

Diameter \_\_\_\_\_ Slot Size \_\_\_\_\_ Screen Length \_\_\_\_\_ ft.

Type \_\_\_\_\_ Material \_\_\_\_\_

Set Between \_\_\_\_\_ ft. and \_\_\_\_\_ ft.

## GRAVEL PACK (Filter Pack)

Material/Size \_\_\_\_\_ Volume/Weight Used \_\_\_\_\_

Method of Installation \_\_\_\_\_

Depth: Placed FROM \_\_\_\_\_ ft. TO \_\_\_\_\_ ft.

## GROUT

Material Binderite Volume/Weight Used 200

Method of Installation Pour

Depth: Placed FROM \_\_\_\_\_ ft. TO \_\_\_\_\_ ft.

## DRILLING LOG\*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

|                | From | To  |
|----------------|------|-----|
| B. Clay        | 0    | 21  |
| G. Clay        | 21   | 38  |
| G. Clay Gravel | 38   | 45  |
| G. Sandy Clay  | 45   | 70  |
| B. Sandy Clay  | 70   | 78  |
| G. Sandy Shale | 78   | 89  |
| B. " "         | 89   | 93  |
| G. " "         | 93   | 100 |
| Coal Fireclay  | 100  | 110 |

water

95

\*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 9/29/10 Total Depth of Well 110 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy