

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT


Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

991655

WELL LOCATION

County Portage Township Mantua
Owner/Builder Mike May
(Circle One or Both) First Last
Address of Well Location 4216 Mennonite Rd
Number Street Name
City Mantua Zip Code +4 44255
Permit No. 04292 Section/Lot No.
(Circle One or Both)
Location of Well in State Plane coordinates, if available:
N X + ft. or m
S Y + ft. or m
Elevation of Well + ft. or m
Datum Plain: NAD27 NAD83 Elevation Source
Source of Coordinates: GPS Survey Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____
North



CONSTRUCTION DETAILS

Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other ☐
BOREHOLE/CASING (measured from ground surface)
1 Borehole Diameter 5.5 inches Depth 75 ft.
Casing Diameter 6 in. Length 42 ft. Thickness 1/8 in.
2 Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Casing Height Above Ground _____ ft.
Type ☒ Steel ☐ Galv. ☐ PVC ☐ Other ☐
Joints ☐ Threaded ☒ Welded ☐ Solvent ☐ Other ☐

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.
Type _____ Material _____
Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____
Method of Installation _____
Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Bentone Volume/Weight Used 100#
Method of Installation Dry Driven
Depth: Placed FROM top ft. TO 42 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Top Soil	0	1
SAND gravel	1	32
BROKEN SANDSTONE	32	40
TAN SANDSTONE	40	75

WELL TEST*

Pre-Pumping Static Level 32 ft. Date 12-15-05
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other
Air ☒ Bailing ☐ Pumping* ☐ Other
Test Rate 20 gpm Duration of Test 2 hrs.
Feet of Drawdown 10 ft. Sustainable Yield 10 gpm
*(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No
Quality _____

PUMP/PITLESS

Type of pump 1/2 sub Goulds Capacity 10 gpm
Pump set at 55 ft. Pitless Type Pickens
Pump installed by HAUBIK Well

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm HAUBIK well Drilling
Address 4943 SR 82
City, State, Zip Mantua OH 44255

Signed [Signature] Date 6-24-05
ODH Registration Number 2285

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 12-15-05 Total Depth of Well 75 ft.