

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

993168

WELL LOCATION

CONSTRUCTION DETAILS

County Licking Township Hartford
Owner/Builder Pauline HaFner
First Last
Address of Well Location 15087 Fairground Rd
Number Street Name
City Croton Zip Code +4 43013
Permit No. 9182 Section/Lot No.
(Circle One or Both)
Location of Well in State Plane coordinates, if available: Use of Well
N ☐ X ☐ +/- ft. or m
S ☐ Y ☐ +/- ft. or m
Elevation of Well 1174' +/- ft. or m
Datum Plain: ☐ NAD27 ☐ NAD83 Elevation Source G.P.S
Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other
BOREHOLE/CASING (measured from ground surface)
1 ☐ Borehole Diameter 5 inches Depth 135 ft.
Casing Diameter 5 in. Length 135 ft. Thickness 1/4 in.
2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.
Casing Height Above Ground 1' ft.
Type 1 ☐ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐
2 ☐ 2 ☐ 2 ☐ Other
Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐
2 ☐ 2 ☐ 2 ☐ Other

SCREEN
Diameter 5 1/4" Slot Size 3/16" Screen Length 2 ft.
Type Perf. Material _____
Set Between 131 ft. and 133 ft.

GRAVEL PACK (Filter Pack)
Material/Size _____ Volume/Weight Used _____
Method of Installation _____
Depth: Placed FROM _____ ft. TO _____ ft.

GROUT
Material Benseal Volume/Weight Used 150 lb.
Method of Installation Dry Pour
Depth: Placed FROM 0 ft. TO 135 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown clay	0	11
Gray clay	11	132
Sand & Gravel	132	135

WELL TEST*

Pre-Pumping Static Level 80 ft. Date 12-22-09
Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other
☐ Air ☒ Bailing ☐ Pumping* ☐ Other
Test Rate 3 gpm Duration of Test 3 hrs.
Feet of Drawdown 30 ft. Sustainable Yield _____ gpm
*(Attach a copy of the pumping test record, per section 1521.05, ORC)
Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No
Quality clearing

PUMP/PITLESS

Type of pump 1/2 hp Myers Capacity 12 gpm
Pump set at 120 ft. Pitless Type Harvard
Pump installed by Dan Allen Well Drilling
I hereby certify the information given is accurate and correct to the best of my knowledge.
Drilling Firm Dan Allen Well Drilling
Address 8972 Columbia Rd
City, State, Zip Pataskala, OH 43062
Signed Karl Allen Date 12-23-09
ODH Registration Number 452

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 12-23-09 Total Depth of Well 135 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy