

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

WELL LOG AND DRILLING REPORT

Ohio Department of Natural Resources
Division of Water, 1939 Fountain Square Drive
Columbus, Ohio 43224-9971 Voice (614) 265-6740 Fax (614) 265-6767

993171

WELL LOCATION

CONSTRUCTION DETAILS

County Licking Township Union

Owner/Builder Gerry Keller
(Circle One or Both) First Last

Address of Well Location 4430 Keller Rd
Number Street Name

City Hebron Zip Code +4 43025

P Permit No. Section/Lot No.
(Circle One or Both)

Location of Well in State Plane coordinates, if available: Use of Well

N X 39° 56' 681 +/- ft. or m

S Y 82° 34' 735 +/- ft. or m

Elevation of Well 900 +/- ft. or m

Datum Plain: NAD27 NAD83 Elevation Source

Source of Coordinates: GPS Survey Other

Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other ☐

BOREHOLE/CASING (measured from ground surface)

1 Borehole Diameter 5 inches Depth 70 ft.

Casing Diameter 5 in. Length 70 ft. Thickness 1/4 in.

2 Borehole Diameter inches Depth ft.

Casing Diameter in. Length ft. Thickness in.

Casing Height Above Ground 2 + ft.

Type 1 Steel 1 Galv. 1 PVC 1 Other

2 2 2 2

Joints 1 Threaded 1 Welded 1 Solvent 1 Other

2 2 2 2

SCREEN

Diameter 5" Slot Size 3/16 Screen Length 4 ft.

Type Perforation Material

Set Between ft. and ft.

GRAVEL PACK (Filter Pack)

Material/Size Volume/Weight Used

Method of Installation

Depth: Placed FROM ft. TO ft.

GROUT

Material Bonsul Volume/Weight Used 80 lbs

Method of Installation Dry Pack

Depth: Placed FROM 20 ft. TO ground level

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Brown top soil	0	20
Gray gritty clay	20	40
Sandy clay	40	49
gravel	49	51
Gray clay	51	53
Very fine sand	53	67
Med sand + gravel	67	70

WELL TEST*

Pre-Pumping Static Level 15 ft. Date 3-18-10

Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other

Air ☒ Bailing ☒ Pumping* ☐ Other

Test Rate 20 gpm Duration of Test 4 hrs.

Feet of Drawdown 0 ft. Sustainable Yield 20 + gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? Yes ☒ No ☐ Flowing Well? Yes ☒ No ☐

Quality

PUMP/PITLESS

Type of pump 1/2 hp Sub Capacity 10 gpm

Pump set at 42 ft. Pitless Type Harvard

Pump installed by Dan Allen Well Drilling

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Dan Allen Well Drilling

Address 8472 Columbus Rd SW,

City, State, Zip Pataskala, Ohio 43062

Signed Dan Allen Date 3-19-10

ODH Registration Number 452

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 3-18-10 Total Depth of Well 70 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 1939 FOUNTAIN SQ. DRIVE, COLS., OHIO 43224-9971

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy