

WELL LOG AND DRILLING REPORT

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

0996148

WELL LOCATION


CONSTRUCTION DETAILS

County Grange Township NewburyOwner/Builder Hummel / Carol
(Circle One or Both) First LastAddress of Well Location 11510 Bell St.
Number Street NameCity 155666 Zip Code +4 44065Permit No. Section/Lot No.
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well DomesticN 41° 26' 086 +/- ft. or m
S 081° 13' 608 +/- ft. or m

Elevation of Well +/- ft. or m

Datum Plain: ☒ NAD27 ☐ NAD83 Elevation Source 1252Source of Coordinates: ☒ GPS ☐ Survey ☐ Other

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other

BOREHOLE/CASING (measured from ground surface)

1 ☐ Borehole Diameter 5.5 inches Depth 96 ft.

Casing Diameter _____ in. Length _____ ft. Thickness _____ in.

2 ☐ Borehole Diameter _____ inches Depth _____ ft.Casing Diameter 6 in. Length 48 ft. Thickness 1.88 in.Casing Height Above Ground 1.4 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐2 ☐ 2 ☐ 2 ☐ OtherJoints 1 ☐ Threaded 1 ☒ Welded 1 ☐ Solvent 1 ☐2 ☐ 2 ☐ 2 ☐ Other

SCREEN

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUT

Material Bentinite Volume/Weight Used 100#Method of Installation Dry DrivenDepth: Placed FROM top ft. TO 48 ft.

DRILLING LOG*

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:

sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Sand gravel 0 10Br. Clay 10 24grey sand gravel clay 24 40Broken sand stone 40 43Brown sand stone 43 96

Water at 76 Feet

WELL TEST*

Pre-Pumping Static Level 45 ft. Date 9-10-05Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other☐ Air ☒ Bailing ☐ Pumping* ☐ OtherTest Rate 22 gpm Duration of Test 2 hrs.Feet of Drawdown 20 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ No

Quality

PUMP/PITLESS

Type of pump Sub Capacity 10 gpmPump set at 80 ft. Pitless Type PickupsPump installed by HAUBIK Well

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm HAUBIK WellAddress 4943 SR 82City, State, Zip Mantua OH 44265Signed H. H. H. Date 9-10-05ODH Registration Number 2285

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 9-11-05 Total Depth of Well 96 ft.Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy