


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

0996623

WELL LOCATION**CONSTRUCTION DETAILS**County Medina Township La FayetteOwner/Builder JIM CAPRON CONST.
(Circle One or Both) First LastAddress of Well Location 7020 West Field Rd
Number Street NameCity Medina Zip Code +4 44256Permit No. 390811 Section/Lot No. _____
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well DomesticN ☒ X N41 04.909 +/- ft. or mS ☐ Y W081 56.380 +/- ft. or mElevation of Well 1130 +/- 25 ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source _____Source of Coordinates: ☒ GPS ☐ Survey ☐ Other _____

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: _____ Long: _____

☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other _____**BOREHOLE/CASING** (measured from ground surface)1 ☐ Borehole Diameter 4 3/4 inches Depth 92 ft.
Casing Diameter 5 in. Length 48 ft. Thickness 250 in.2 ☐ Borehole Diameter _____ inches Depth _____ ft.
Casing Diameter _____ in. Length _____ ft. Thickness _____ in.Casing Height Above Ground 12 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ _____
2 ☐ _____ 2 ☐ _____ 2 ☐ _____ 2 ☐ Other _____**SCREEN**

Diameter _____ Slot Size _____ Screen Length _____ ft.

Type _____ Material _____

Set Between _____ ft. and _____ ft.

GRAVEL PACK (Filter Pack)

Material/Size _____ Volume/Weight Used _____

Method of Installation _____

Depth: Placed FROM _____ ft. TO _____ ft.

GROUTMaterial BENTONITE Volume/Weight Used 50 LBSMethod of Installation dry pourDepth: Placed FROM 0 ft. TO 48 ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation:
sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
<u>yellow clay</u>	<u>0</u>	<u>12</u>
<u>gray clay + sand</u>	<u>12</u>	<u>45</u>
<u>gray shale rock</u>	<u>45</u>	<u>92</u>

WELL TEST*Pre-Pumping Static Level 3 ft. Date 12-29-10Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other _____☐ Air ☒ Bailing ☐ Pumping* ☐ Other _____Test Rate 10 gpm Duration of Test 1 hr hrs.Feet of Drawdown 18 ft. Sustainable Yield 10 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality clean**PUMP/PITLESS**Type of pump SUB. Capacity 10 gpmPump set at 80 ft. Pitless Type slidePump installed by GRAHAM WATER SERVICE

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm GRAHAM WATER SERVICEAddress 5145 COLUMBIACity, State, Zip Medina OH 44256Signed George Graham Date 1-5-11ODH Registration Number 1310

*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 12-31-10 Total Depth of Well 92 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy