

**WELL LOG AND DRILLING REPORT**TYPE OR USE PEN  
SELF TRANSCRIBING  
PRESS HARD

Ohio Department of Natural Resources


Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

0996625

**WELL LOCATION****CONSTRUCTION DETAILS**County Medina Township HARRISVILLEOwner/Builder Kevin Carpenter  
(Circle One or Both) First LastAddress of Well Location 8410 La Fayette Rd  
Number Street NameCity Lodi Zip Code +4 44254Permit No. 390850 Section/Lot No. \_\_\_\_\_  
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well DOMESTICN ☐ X ☐ +/- \_\_\_\_\_ ft. or mS ☐ Y ☐ +/- \_\_\_\_\_ ft. or mElevation of Well 1130 50 +/- 50 ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source GPSSource of Coordinates: ☒ GPS ☐ Survey ☐ Other \_\_\_\_\_

Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: \_\_\_\_\_ Long: \_\_\_\_\_

N41-02-643 North W081 59.967**WELL TEST\***Pre-Pumping Static Level 33 ft. Date 6-10-11Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other \_\_\_\_\_Air ☐ Bailing ☒ Pumping\* ☐ Other \_\_\_\_\_Test Rate 10 gpm Duration of Test 1 hrs.Feet of Drawdown 3 ft. Sustainable Yield 15 gpm

\*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☒ NoQuality Clear**PUMP/PITLESS**Type of pump SUB Capacity 12 gpmPump set at 70 ft. Pitless Type SLIDEPump installed by GRAHAM

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm GRAHAM WATER SERVICEAddress 5145 COLUMBIA RDCity, State, Zip Medina OH 44256Signed George Graham Date 6-14-11ODH Registration Number 310☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other \_\_\_\_\_**BOREHOLE/CASING** (measured from ground surface)1 | Borehole Diameter 4 3/4 inches Depth 80 ft.Casing Diameter 5 in. Length 61 ft. Thickness .275 in.

2 | Borehole Diameter \_\_\_\_\_ inches Depth \_\_\_\_\_ ft.

Casing Diameter \_\_\_\_\_ in. Length \_\_\_\_\_ ft. Thickness \_\_\_\_\_ in.

Casing Height Above Ground 12 4 ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other \_\_\_\_\_2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other \_\_\_\_\_Joints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other \_\_\_\_\_2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other \_\_\_\_\_**SCREEN**

Diameter \_\_\_\_\_ Slot Size \_\_\_\_\_ Screen Length \_\_\_\_\_ ft.

Type \_\_\_\_\_ Material \_\_\_\_\_

Set Between \_\_\_\_\_ ft. and \_\_\_\_\_ ft.

**GRAVEL PACK** (Filter Pack)

Material/Size \_\_\_\_\_ Volume/Weight Used \_\_\_\_\_

Method of Installation \_\_\_\_\_

Depth: Placed FROM \_\_\_\_\_ ft. TO \_\_\_\_\_ ft.

**GROUT**Material BENONIGHT Volume/Weight Used 50 LBSMethod of Installation DRY POURDepth: Placed FROM 0 ft. TO 60 ft.**DRILLING LOG\***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

|                         | From | To |
|-------------------------|------|----|
| yellow clay             | 0    | 20 |
| Gray clay sand & gravel | 20   | 38 |
| Gray sand & gravel      | 38   | 60 |
| Gray sand Rock          | 60   | 80 |

\*(If more space is needed to complete drilling log, use next consecutively numbered form.)

Date of Well Completion 6-10-11 Total Depth of Well 80 ft.

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy