


WELL LOG AND DRILLING REPORTTYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARDOhio Department of Natural Resources
Division of Water, 2045 Morse Road

Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

0996638

WELL LOCATION**CONSTRUCTION DETAILS**County Lark Township JuscarawasOwner/Builder Steve Ounis
(Circle One or Both) First LastAddress of Well Location 14711 Millersburg Road
Number Street NameCity Navarre Zip Code +4 44662Permit No. 22589/380313 Section/Lot No.
(Circle One or Both)Location of Well in State Plane coordinates, if available: Use of Well ResidentialN ☐ X ☒ ft. or m
S ☐ Y ☒ ft. or mElevation of Well See Below ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation Source Source of Coordinates: ☒ GPS ☐ Survey ☐ Other Sketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: 40.741607° Long: 81.6339°Elev: 1141 ft.
N: 04° 44.502'
W: 081° 38.034' Older well building**WELL TEST***Pre-Pumping Static Level 66 ft. Date 6-4-07Measured from: ☒ Top of Casing ☐ Ground Level ☐ Other ☐ Air ☒ Bailing ☐ Pumping* ☐ Other Test Rate 15 gpm Duration of Test 1 hrs.Feet of Drawdown 30 ft. Sustainable Yield 15 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☒ No Flowing Well? ☐ Yes ☒ NoQuality Clear**PUMP/PITLESS**Type of pump Submersible Capacity 1/2 hp 17 gpmPump set at 129 ft. Pitless Type DickensPump installed by Rick Williams

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm Williams Drilling Co.Address 15255 Starnapped Rd. SECity, State, Zip Patton, Ohio 44618Signed Phil Williams Date 6-4-07ODH Registration Number 2212☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other **BOREHOLE/CASING** (measured from ground surface)1 ☒ Borehole Diameter 8 inches Depth 100 ft. Thickness SPR 21 in.Casing Diameter 5 in. Length 100 ft. Thickness in.2 ☐ Borehole Diameter inches Depth ft.Casing Diameter in. Length ft. Thickness in.Casing Height Above Ground 14+ ft.Type 1 ☐ Steel 1 ☐ Galv. 1 ☒ PVC 1 ☐2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ Other SPR 21Joints 1 ☐ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other **SCREEN**Diameter Slot Size Screen Length ft.Type Material Set Between ft. and ft.**GRAVEL PACK** (Filter Pack)Material/Size Volume/Weight Used Method of Installation Depth: Placed FROM ft. TO ft.**GROUT**Material Benseal Volume/Weight Used 200 galMethod of Installation Set with tremmieDepth: Placed FROM 96 ft. TO Surface ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

	From	To
Drift	0	8
Sand, gravel, clay	8	27
Sand, Clay	27	78
Sandstone	78	80
Shale	80	190

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.

ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605

Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy