

WELL LOG AND DRILLING REPORT

0997111

TYPE OR USE PEN
SELF TRANSCRIBING
PRESS HARD

Ohio Department of Natural Resources

Division of Water, 2045 Morse Road


Columbus, Ohio 43229-6605 Voice (614) 265-6740 Fax (614) 265-6767

WELL LOCATION**CONSTRUCTION DETAILS**County Pickaway Township HarrisonOwner/Builder (Circle One or Both) Willis, RobertAddress of Well Location 3945 Miller Rd
Number Street NameCity Ashville Zip Code +4 3232Permit No. 07-009 Section/Lot No. (Circle One or Both)

Location of Well in State Plane coordinates, if available:

N ☒ X +/- ft. or mS ☐ Y +/- ft. or mElevation of Well +/- ft. or mDatum Plain: ☐ NAD27 ☐ NAD83 Elevation SourceSource of Coordinates: ☐ GPS ☐ Survey ☐ OtherSketch a map showing distance well lies from numbered state highways, street intersections, county roads, buildings or other notable landmarks. If latitude and longitude are available please include here: Lat: Long:

North

**WELL TEST***Pre-Pumping Static Level 20 ft. Date Measured from: ☐ Top of Casing ☐ Ground Level ☐ Other☐ Air ☒ Bailing ☒ Pumping* ☐ OtherTest Rate 12 gpm Duration of Test 3 hrs.Feet of Drawdown 2 ft. Sustainable Yield 12 gpm

*(Attach a copy of the pumping test record, per section 1521.05, ORC)

Is Copy Attached? ☐ Yes ☐ No Flowing Well? ☐ Yes ☐ NoQuality **PUMP/PITLESS**Type of pump Arj Jacket Capacity 12 gpmPump set at 35 ft. Pitless Type pull throughPump installed by Water Bay

I hereby certify the information given is accurate and correct to the best of my knowledge.

Drilling Firm A Water Bay DrillingAddress 14270 Walnut Creek PikeCity, State, Zip Ashville, Ohio 43103Signed Jim D. Wray Date 3-31-07ODH Registration Number 02775☐ Rotary ☒ Cable ☐ Augered ☐ Driven ☐ Other**BOREHOLE/CASING** (measured from ground surface)1 ☒ Borehole Diameter 5" inches Depth 47 ft.Casing Diameter 5" in. Length 47 ft. Thickness 1.68 in.2 ☐ Borehole Diameter inches Depth ft.Casing Diameter in. Length ft. Thickness in.Casing Height Above Ground 18" ft.Type 1 ☒ Steel 1 ☐ Galv. 1 ☐ PVC 1 ☐ Other2 ☐ Steel 2 ☐ Galv. 2 ☐ PVC 2 ☐ OtherJoints 1 ☒ Threaded 1 ☐ Welded 1 ☐ Solvent 1 ☐ Other2 ☐ Threaded 2 ☐ Welded 2 ☐ Solvent 2 ☐ Other**SCREEN**Diameter 5" Slot Size 1/4" Screen Length 3' ft.Type Steel Material Set Between 47 ft. and 43 ft.**GRAVEL PACK** (Filter Pack)Material/Size Volume/Weight Used Method of Installation Depth: Placed FROM ft. TO ft.**GROUT**Material Dry Grout Volume/Weight Used 2010Method of Installation Dry DrivenDepth: Placed FROM ft. TO ft.**DRILLING LOG***

INDICATE DEPTH(S) AT WHICH WATER IS ENCOUNTERED.

Show color, texture, hardness, and formation: sandstone, shale, limestone, gravel, clay, sand, etc.

From To

Soil 0 2

Yellow 2 22

Clay clay 22 42

Sand gravel 42 47

Completion of this form is required by section 1521.05, Ohio Revised Code - file within 30 days after completion of drilling.
ORIGINAL COPY TO - ODNR, DIVISION OF WATER, 2045 MORSE ROAD, COLS., OHIO 43229-6605
Blue - Customer's copy Pink - Driller's copy Green - Local Health Dept. copy